



भारतीय मानक ब्यूरो
BUREAU OF INDIAN STANDARDS
Bangalore Branch Office

Address:Peenya Industrial Area,1st Stage,
Bangalore-Tumkur Road,
Bangalore-560058.
Phones : 080-28394955, 28394956
Fax: 080-28398841
E-Mail: bnbo@bis.org.in
web : <http://www.bis.org.in>

Our Ref.:BNBO /L -6139768

12 Nov 2008

M/s SBEE CABLES (INDIA) LTD
NO.29, J C W INDL AREA, 11TH KM,
KANAKAPURA ROAD,
BANGALORE-560062.

Dear Sir(s),

This has reference to BIS Certification Marks Licence No. CML/L- 6139768 held by you for PVC Insulated cables for working voltages upto and including 1100 V as per IS 694 : 1990 which is valid upto 04/11/2009.

We are pleased to inform you that the Competent Authority of Bureau has agreed to include the following variety in your licence with immediate effect :
PVC Insulated cables for working voltages upto and including 1100 V as per the following ratings :
Category C-2 of sizes already covered in the licence for improved fire performance excluding for Low temperature and weather proof performance

With this inclusion,the varieties of PVC Insulated cables for working voltages upto and including 1100 V covered in your licence no.CM/L-6139768 as per IS IS 694 : 1990 are as follows :


PVC Insulated cables for working voltages upto and including 1100 V as per the following ratings :

SINGLE CORE,UNSHEATHED CABLE UPTO AND INCLUDING 25 MM SQ SIZE COPPER CONDUCTOR CLASS 5, TYPE A SINGLE CORE STRANDED A1 CONDUCTOR CLASS 2 UNSHEATHED CABLE UPTO AND INCLUDING 240 MM SQ SINGLE CORE STRANDED COPPER CONDUCTOR CLASS 2 UNSHEATHED CABLE UPTO AND INCLUDING 240 MM SQ 3 CORE FLAT CABLE COPPER STRANDED CONDUCTOR CLASS 2 FOR SIZE UPTO AND INCLUDING 50 MM SQ 4 CORE STRANDED COPPER CONDUCTOR CLASS 2 CIRCULAR CABLE SIZE UPTO AND INCLUDING 50 MM SQ

Please inform us as and when you start marking the new variety. You are advised to maintain separate records for the above variety after testing the same as per STI.

Endorsement sheet No. 15 for the above is enclosed.

Thanking You,

Yours faithfully,

12/11/2008 (C M SINGE)
SCIENTIST-E (Director)



भारतीय मानक ब्यूरो
BUREAU OF INDIAN STANDARDS

Address : Peenya Industrial Area, 1st Stage,
Bangalore-Tumkur Road,
Bangalore – 560058.

Phones : 080-28394955, 28394956

Fax : 080-28398841

E-mail : bnbo@bis.org.in

Web : http://www.bis.org.in

Bangalore Branch Office

ATTACHMENT TO LICENCE NO. CM/L- 6139768

<u>CML NO</u>	<u>NAME OF THE LICENSEE WITH ADDRESS</u>	<u>PRODUCT</u>	<u>IS NO</u>
6139768	SBEE CABLES (INDIA) LTD NO.29, J C W INDL AREA, 11TH KM, KANAKAPURA ROAD, BANGALORE-560062.	Pvc insulated cables for working voltages upto and including 1100 v	IS 694 : 1990

ENDORSEMENT NO. 15

Dated 12 11 2008

The following additional (type) has been included in Columns(2) of the first schedule and column (1) of the the Second Schedule of the Licence alongwith the Standard Mark in Column (1) of First Schedule with effect from Seventh November, Two Thousand Eight.

Category C-2 of sizes already covered in the licence for improved fire performance excluding for low temperature and weather proof performance.

Other terms and conditions of Licence remain the same.

(C M SINGE)

SCIENTIST-E (Director)